

Call for tenders' details

Title: Installation of 2 air coolers and 2 free-cooling heat exchangers. Full-guarantee maintenance of the installations.

Start date: 13/05/2016

Time limit for receipt of tenders: 29/06/2016

Contracting authority: European Commission, Office for Infrastructure and Logistics in Luxembourg (OIL)

Status: Closed

Call for tenders question list

#	Submission date	Publication date	Question subject	Question	Answer
1	15/06/2016 15:59	15/06/2016 16:05	Niveau sonore des a�ror�frig�rants	Pourriez-vous pr�ciser le niveau sonore � respecter pour les a�ror�frig�rants?	15/06/2016 Comme annonc� dans le point 7 de l'annexe I.B., le niveau sonore doit �tre d�termin� suivant les normes ISO 3741 et ISO 3744. Il n'y a pas d'autres pr�cisions � apporter.
2	15/06/2016 16:02	15/06/2016 16:08	Plage de fonctionnement de l'a�ror�frig�rant	Que doit-on comprendre de la phrase: L'a�ror�frig�rant pourra fonctionner dans une plage de temp�rature allant de -30 � + 45 �C, sachant que l'a�ror�frig�rant est dimensionn� pour 32 �C ext�rieur?	15/06/2016 L'a�ror�frig�rant doit fournir sa puissance +-10% pour 32�C ext�rieur. Il doit n�anmoins pouvoir fonctionner (� puissance r�duite) jusqu'� 45 �C ext�rieur.