

Call for tenders' details

Title: Refurbishment of the Entrance of EMSA's Building

Start date: 02/12/2020

Time limit for receipt of tenders: 04/02/2021

Contracting authority: European Maritime Safety Agency

Status: Closed

Call for tenders question list

#	Submission date	Publication date	Question subject	Question	Answer
1	07/01/2021 10:06	07/01/2021 12:47	Visita ao Local da Obra	Bom Dia Pretendo marcar uma vista ao local da obra. Quando é possível ?	07/01/2021 As per Point 12 of the Invitation to Tender, "To schedule an on-site visit, an e-mail shall be sent to the dedicated e-mail address: OPEN392020@emsa.europa.eu no later than 4 January 2021."

Call for tenders questions summary

#	Submission date	Publication date	Question subject	Question	Answer
2	15/01/2021 16:51	22/01/2021 10:43	Subcontracting information	Must we present all the Documents requested in the Selection Criteria (14.3, 14.4, 14.5 and 14.6) for us and also each subcontractor regardless the % of subcontracting we may have for the works? Or is it enough our evidence?	22/01/2021 As per Point 9 of the Tender Specifications, "The tenderer must provide required evidence for the exclusion and selection criteria on its own behalf and, when applicable, on behalf of its subcontractors. The evidence for the selection criteria on behalf of subcontractors must be provided where the tenderer relies on the capacities of subcontractors to fulfil selection criteria . To rely on the capacities of a subcontractor means that the subcontractor will perform the works or services for which these capacities are required."
3	11/01/2021 19:21	22/01/2021 18:59	Clarifications - 1	Are there any specific requirements for fencing and protect the working areas?	22/01/2021 No specific requirements. The intervention areas must be clearly indicated, signposted and have a protection perimeter, that allows the normal functioning of the Agency and the safeguard of the intervening personnel. Personnel must be equipped with personal protective equipment in accordance with current H&S regulations.

Call for tenders questions summary

#	Submission date	Publication date	Question subject	Question	Answer
4	11/01/2021 19:21	22/01/2021 18:59	Clarifications - 2	Are there any specific requirements for the cleaning during the performance of the works?	22/01/2021 No specific requirements. Given the sensitivity of the technical equipment and building installations (CCTV, fire detection system, etc.), the intervention areas should be properly isolated and protected to avoid any dust pollution and/or dirt contamination of the adjacent areas of the building.
5	11/01/2021 19:21	22/01/2021 19:00	Clarifications - 3 a)	Regarding the Quantity Map (Articulado/MQT): - Art 5.2.3 e 5.2.4 : the units of measurement shouldn't be "un"?	22/01/2021 We confirm that, in Art. 5.2.3 e 5.2.4 of Appendix 4, the unit should be "un" and not "m2".
6	11/01/2021 19:21	22/01/2021 19:01	Clarifications - 3 b)	Regarding the Quantity Map (Articulado/MQT): - Art 7.1.1.5 e 7.1.1.6: we request the identification of the doors with retainers with or without alarm. In the list both are indicated as having alarm.	22/01/2021 Art 7.1.1.5 is without alarm (instead of with alarm as announced), the identification is S04 / E4A (descendente) / 01.1, 3 units instead of 5. Art 7.1.1.6 is with alarm (de porta aberta), the identification is S02a / S02 / PA1 / E4A (ascendente) / 01.60, 5 units instead of 3. Appendix 4 has been republished with the adjusted information.

Call for tenders questions summary

#	Submission date	Publication date	Question subject	Question	Answer
7	11/01/2021 19:21	22/01/2021 19:02	Clarifications - 3 c)	Regarding the Quantity Map (Articulado/MQT): - Art 8.1.12: The quantities of circular registers regulating flow are different from the EN-Appendix 2 to the TS - Project_mechanical part	22/01/2021 The units in Art 8.1.12 of Appendix 4 should be 6 instead of 4. A new Art 8.12.a is also inserted: 8.1.12a - Registos circulares para regulação de caudal DN160, de comando manual, na condição de pronto a funcionar, de acordo com o especificado no Projeto, incluindo todos os trabalhos preparatórios e acessórios. – un - 2.00. Appendix 4 has been republished with the adjusted information.
8	11/01/2021 19:21	22/01/2021 19:03	Clarifications - 3 d)	Regarding the Quantity Map (Articulado/MQT): -Art 8.1.25: Quantity vs dimension and location of the 4 trapdoors	22/01/2021 In Art 8.1.25 of Appendix 4, the dimension to take into account shall be 45x45 cm instead of 50x50cm and the unit should be 1 instead of 4 (room 0.21 only). Appendix 4 has been republished with the adjusted information.

Call for tenders questions summary

#	Submission date	Publication date	Question subject	Question	Answer
9	11/01/2021 19:21	22/01/2021 19:03	Clarifications - 3 e)	Regarding the Quantity Map (Articulado/MQT): - Art 8.1: where is considered the work "Desmontagem cuidado de equipamento e condutas nas salas 0.3, 0.82 e 0,81, incluindo trabalhos de adaptação dos plenos e grelhas existentes, colocação de rede de tamponamento de tubagem aberta na sala 0.82".	22/01/2021 The indicated item is not considered as necessary. Please follow the technical solution according to the file 'Appendix 4 to the TS - BoQ total_all parts' and drawing no. M-003 ('tubagem aberta com rede de protecção').
10	11/01/2021 19:21	22/01/2021 19:04	Clarifications - 3 f)	Regarding the Quantity Map (Articulado/MQT): - Art. 8.1.16: we request the confirmation of the filter dimensions [592x592x48].	22/01/2021 The FC-0.2 and FC-0.75 filters are oversized for safety reasons and exceptional situations (as in case of the current pandemic situation). They must be installed in a DN100 duct. The C500 box (France-Air reference model) has DN500 outlets, thus the project includes additional two reductions, one on each side. The dimensions of the filters and the filter box are thus confirmed (592x592x48).

Call for tenders questions summary

#	Submission date	Publication date	Question subject	Question	Answer
11	22/01/2021 17:25	22/01/2021 19:18	New Answer deadline	We've still some clarifications request with no answer and due to the new answer deadline, it may means that you may answer after the Offer submission deadline? Question deadline 27/01/2021 16:00 UTC Updated Answer deadline 29/01/2021 23:59 UTC Updated Time limit for receipt of tenders 29/01/2021 16:00 UTC In order to have our Offer ready we need that EMSA may answer our Clarifications before tender's submission deadline. Thanks in advance for your kind attention.	22/01/2021 Please note that the deadline to reply submitted questions has been postponed to 29/01/2021 (6 days) because the bid submission deadline has also been postponed to 04/02/2021 (6 days). Please note that all questions received have been replied to.

Generated on the 18/04/2024 17:11:12 - Generation time 5 ms